Agenda Item III.7

Bristol Town Administrator

From: Jill Marsano <jill@vtums.com>
Sent: Wednesday, July 8, 2020 11:24 PM
To: Bristol Town Administrator
Cc: Joel Bouvier
Subject: Damaged Curb Stops on South Side of East Street for Discussion w/ VTrans Tomorrow
Attachments: IMG_6650.JPG; IMG_6649.JPG; IMG_6641.JPG; IMG_6642.JPG; IMG_6647.JPG; IMG_6648.JPG

Valerie,

Attached are pictures of the 3 customer curb boxes on the south side of East Street that were damaged by the contractor's excavator bucket when working in the green space over the past few weeks. Cyrus did ask Brandyn Gadapee this morning when they would be repairing this damage, to which he replied not right now as they are incredibly busy trying get the project done.

We'd like to assure the contractor and State are aware of the damage and propose that the Town (through VTUMS) performs these repairs efficiently and to their standards and invoices the contractor.

In addition, there are still a number of valve boxes that were damaged by the pavement grinder. We would like to understand when these will be repaired prior to paving to assure they will not have risers thrown on top of the damage (leaving voids for dirt and water to enter) versus fixed with risers added to bring to grade so the valve boxes are fully accessible and solid after the project.

As discussed earlier today, please forward me the Zoom meeting invite for the 11:30 am VTrans meeting tomorrow, and I will login to attend.

Thanks,

Jill Marsano
Owner/President
VTUMS Vermont Utility Management Services, LLC