



**Town of Bristol**  
Town Administrator  
1 South Street  
P.O. Box 249  
Bristol, VT 05443  
(802) 453-2410 x 1  
[townadmin@bristolvt.org](mailto:townadmin@bristolvt.org)  
[www.bristolvt.org](http://www.bristolvt.org)

December 15, 2021

Kevin R. LaRose, LS  
LaRose Surveys, PC  
P.O. Box 388  
25 West Street  
Bristol, Vermont 05443  
Via e-mail: [larosesurveys@gmail.com](mailto:larosesurveys@gmail.com)

RE: 48 Mountain Terrace Ability to Serve Confirmation

Dear Mr. LaRose:

We are in receipt of your request on behalf of your client Tom and Claire Wallace regarding the subdivision of their property at 48 Mountain Terrace and confirmation of the municipal water system's ability to provide an additional allocation of water of 420 gallons per day for a new three-bedroom residence.

Please accept this letter as confirmation that this service can be provided. The spring source is permitted at 568 gallons per minute and is sufficient to meet current average daily flows of approximately 260,000 gallons per day. The source water is pumped to a storage reservoir with a usable capacity of 632,000 gallons. We expect no adverse effect on pressure, fire flows, or storage as a result of the proposed additional allocation.

Please contact me if you need any additional information at 453-2410 or e-mail me at [townadmin@bristolvt.org](mailto:townadmin@bristolvt.org).

Sincerely,

Valerie Capels  
Town Administrator

Cc: Water Commission  
Bristol Town Clerk (via e-mail: [clerk@bristolvt.org](mailto:clerk@bristolvt.org))  
Bristol Town Treasurer (via e-mail: [treasurer@bristolvt.org](mailto:treasurer@bristolvt.org))  
VTUMS, Water Operator (via e-mail: [info@vtums.com](mailto:info@vtums.com))  
Green Mountain Engineering, Inc. (via e-mail: [ahuizenga@gmeinc.biz](mailto:ahuizenga@gmeinc.biz))