



**Town of Bristol**  
Town Administrator  
1 South Street  
P.O. Box 249  
Bristol, VT 05443  
(802) 453-2410 x 1  
[townadmin@bristolvt.org](mailto:townadmin@bristolvt.org)  
[www.bristolvt.org](http://www.bristolvt.org)

June 8, 2022

Kevin R. LaRose, LS  
LaRose Surveys, PC  
P.O. Box 388  
25 West Street  
Bristol, Vermont 05443  
Via e-mail: [larosesurveys@gmail.com](mailto:larosesurveys@gmail.com)

RE: Len Letersky and Dee LeFlam at 139 North Street

Dear Mr. LaRose:

We are in receipt of your revised request on behalf of your clients Len Letersky and Dee LeFlam, who own property at 139 North Street, for confirmation that the municipal water system has the ability to provide an additional allocation for two (2) three-bedroom, single-family residences at 420 gpd per residence, totaling 840 gallons per day.

Please accept this letter as confirmation that this service can be provided. The spring source is permitted at 568 gallons per minute and is sufficient to meet current average daily flows of approximately 223,000 gallons per day. The source water is pumped to a storage reservoir with a usable capacity of 632,000 gallons. We expect no adverse effect on pressure, fire flows, or storage as a result of the proposed additional allocations.

Please note that applications and Water Commission approval will be required for connection to the system and review of the updated Bristol Water Use Ordinance (October 2021) is advised. Please contact me if you need any additional information at 453-2410 or e-mail me at [townadmin@bristolvt.org](mailto:townadmin@bristolvt.org).

Sincerely,

Valerie Capels  
Town Administrator

Cc: Water Commission  
Bristol Town Clerk (via e-mail: [clerk@bristolvt.org](mailto:clerk@bristolvt.org))  
Bristol Town Treasurer (via e-mail: [treasurer@bristolvt.org](mailto:treasurer@bristolvt.org))  
VTUMS, Water Operator (via e-mail: [info@vtums.com](mailto:info@vtums.com))  
VTM Engineering, PLC (via e-mail: [spalmer@vtmengineering.com](mailto:spalmer@vtmengineering.com))