

**APPLICATION FOR PERMIT  
To Work in the Bristol Town Right-of-Way**

Date 8-23-22 Parcel ID # \_\_\_\_\_ TH # 318

Applicant Deborah Cossaart

Mailing address PO Box 265 Bristol 05443

E-mail address debcoossaart@gmail.com

Property location 73 Maple St Bristol

**\* Attach a sketch showing street/road and location of proposed work. \***

Name of Company or Individual doing excavation Matt Atkins

Company or Individual address and phone number 3575 Downingville Rd  
Lincoln, VT 05443

Describe project (including length, width & depth of proposed excavation) \_\_\_\_\_

Excavation of one ditch 10 feet in width with the power and phone  
on one side of the ditch at a depth of 3' and the water on the opposite side 6' deep

Date of start of work \_\_\_\_\_ Date of completion \_\_\_\_\_

The applicant agrees to accept the permit on the terms and conditions as specified, which permit is issued, based upon the information provided by the applicant.

Deborah Cossaart  
Applicant's signature

8-23-22  
Date

Additional conditions per order of the Public Works Foreman: same conditions as

Driveway permit, the crossing for power and water shall be  
littered back in, in lifts (12") and compacted with suitable material.  
The last 12" shall be crushed gravel and there shall be 2" inches  
of pavement put in, and lifts each lift shall be compacted. Sidewalk  
can be 4" inch thick, minimum 4000 lb mix. What is grass now shall  
be put back to grass, seeded and mulched. any questions call 453-4707.

Eric Cote  
Public Works Foreman (or designee) signature

9-2-22  
Date

=====  
\$250 deposit: Date paid 8.31.22

Received by SL

Release of deposit authorized by: \_\_\_\_\_ Date \_\_\_\_\_

Tree to be trimmed to  
improve line of sight

Drive  
way

Existing pole



Site work  
to be  
removed and new  
conduit  
to be  
poured after  
excavation is  
complete

Proposed path of new conduit  
3' deep

10'

New Water line

Curb  
stop

MAPLE STREET

Not to scale

Property line

40'

Proposed drive way

20'

Existing pole  
to be  
removed



\* Where  
power crosses  
water at least 3'  
V of separation

30'

Existing Maple



(Orchids planted to neighbors  
house)

New House  
foundation

73  
MAPLE