



**Wastewater System and Potable Water Supply Permit #WW-9-0682-2**

**D. Chad & Michelle S. Perlee**

**Bristol**

**page 2 of 3**

- 1.5 By acceptance of this permit, the landowner agrees to allow representatives of the State of Vermont access to the property covered by the permit, at reasonable times, for the purpose of ascertaining compliance with the Vermont environmental and health statutes and regulations.
- 1.6 A copy of the approved plans and this permit shall remain on the project during all phases of construction, and upon request, shall be made available for inspection by State or local officials.
- 1.7 In issuing this permit, the Division has relied solely upon the licensed designer's certification that the design-related information submitted was true and correct, and complies with the Vermont Wastewater System and Potable Water Supply Rules and the Vermont Water Supply Rules. This permit may be revoked if it is determined that the project does not comply with these Rules.
- 1.8 No permit issued by the Secretary shall be valid for a substantially completed potable water supply and wastewater system until the Secretary receives a certification from a designer signed and dated, that states:  
"I hereby certify that, in the exercise of my reasonable professional judgment, the installation-related information submitted is true and correct and the municipal water supply and wastewater system were installed in accordance with the permitted design and all the permit conditions, were inspected, were properly tested, and have successfully met those performance tests",  
  
or which otherwise satisfies the requirements of §1-308 and §1-911 of the referenced rules.
- 1.9 This permit shall in no way relieve the permittee of the obligations of V.S.A. Title 10, Chapter 48, Subchapter 4, for the protection of groundwater.
- 1.10 Any person aggrieved by this permit may appeal to the Environmental Court within 30 days of the date of issuance of this permit in accordance with 10 V.S.A. Chapter 220 and the Vermont Rules of Environmental Court Proceedings.

**2. WATER SUPPLY**

- 2.1 The lot is approved for water supply by connection to the Bristol municipal water system. No other means of obtaining potable water shall be allowed without prior review and approval by the Division of Wastewater Management.

**3. WASTEWATER DISPOSAL**

- 3.1 The lot is approved for wastewater disposal by construction and utilization of the site-specific wastewater disposal system depicted on the approved plans. No other method or location of wastewater disposal shall be allowed without prior review and approval by the Division of Wastewater Management.
- 3.2 The on-site, subsurface wastewater treatment/disposal system herein approved shall be routinely and reliably inspected during construction by a Class 1 designer or a Type A or B licensed designer shall, upon completion and prior to occupancy of the subject establishment, report in writing to the Division of Wastewater Management that the installation was accomplished in accordance with the approved plans and permit conditions.

**Wastewater System and Potable Water Supply Permit #WW-9-0682-2**

**D. Chad & Micelle S. Perlee**

**Bristol**

**page 3 of 3**

3.3 The wastewater disposal system herein approved shall be operated at all times in a manner that will not permit the discharge of sewage/effluent onto the ground surface or into the waters of the State.

3.4 The future wastewater disposal "replacement area" designated on the approved plans shall be held in reserve for the eventual construction of a replacement disposal system in the event of failure of the primary system. No construction, earthwork, or other activity shall be allowed within the replacement area which would diminish its natural suitability for such eventual use as a wastewater disposal site.

3.5 The wastewater disposal system was designed and the project is approved based on the anticipated daily volume of wastewater from 490 gpd. There shall be no expansion of the project or increase in occupancy beyond this basis of design without prior review and approval by the Division of Wastewater Management.

David K. Mears, Commissioner  
Department of Environmental Conservation

By Raymond Dean  
Raymond Dean  
Assistant Regional Engineer

Dated at Rutland, Vermont this 31 day of March 2011.

cc: Town Planning, Bristol  
Kevin Larose