



SEE TRENCH
DETAIL FOR
BEDDING/BACKFILL
SPECIFICATIONS

NOTES
 1. SPIRAL WRAP TEFLON THREAD SEALANT TAPE ON ALL CORPORATION STOPS. LIQUID THREAD SEALANTS ARE NOT ACCEPTABLE..
 2. ALL BOXES TO BE RAISED TO GRADE WITH NO USE OF INSERTS.

**TYPICAL SERVICE
 CONNECTION DETAIL - 3/4" ~ 2"**
 NOT TO SCALE

- EQUIPMENT SPECIFICATIONS**
1. ALL MATERIALS SHALL BE AWWA/NSF CERTIFIED AND APPROVED BY THE TOWN.
 2. SADDLE - ROMAC 202NS
 3. CORP STOP - BRASS NL STYLE WITH 250 psi MIN.
 4. CURB STOP - BRASS NL STYLE WITH 250 psi MIN.
 5. COPPER TUBING - TYPE 'K', SEAMLESS, 250 psi MIN.
 6. CHECK VALVES - BRASS SWING CHECK, 250 psi MIN.
 7. CURB BOX - SLIP TYPE CAST IRON
 8. BALL VALVES - BRASS BALL VALVES, 250 psi MIN.
 9. METER - (3/4" - 2") - SUPPLIED BY TOWN

**TYPICAL SERVICE
 CONNECTION DETAIL**

TOWN OF BRISTOL
 1 SOUTH STREET, P.O. BOX 249
 BRISTOL, VT 05443
 (802) 453-2410



DRAWING
W-2