



**MANHOLE SPECIFICATIONS**

(CAMP PRECAST STANDARD OR EQUIV.)

- CONCRETE MINIMUM STRENGTH-5,000 psi @ 28 DAYS
- MEETS ASTM C478
- H-20 LOADING
- WEIGHTS SUBJECT TO VARIATION

**EQUIPMENT SPECIFICATIONS**

1. ALL MATERIALS SHALL BE AWWA/NSF CERTIFIED AND APPROVED BY THE TOWN.
2. SADDLE - ROMAC 202NS
3. CORP STOP - BRASS NL STYLE WITH 250 psi MIN.
4. CURB STOP - BRASS NL STYLE WITH 250 psi MIN.
5. COPPER TUBING - TYPE 'K', SEAMLESS, 250 psi MIN.
6. CHECK VALVES - BRASS SWING CHECK, 250 psi MIN.
7. CURB BOX - SLIP TYPE CAST IRON
8. BALL VALVES - BRASS BALL VALVES, 250 psi MIN.
9. METER - (3/4" - 2") - SUPPLIED BY TOWN

**STANDARD METER  
PIT DETAIL**

**TOWN OF BRISTOL**  
1 SOUTH STREET, P.O. BOX 249  
BRISTOL, VT 05443  
(802) 453-2410



DRAWING

**W-1**