



SEE TRENCH
DETAIL FOR
BEDDING/BACKFILL
SPECIFICATIONS

- NOTES**
1. SPIRAL WRAP TEFLON THREAD SEALANT TAPE ON ALL CORPORATION STOPS. LIQUID THREAD SEALANTS ARE NOT ACCEPTABLE..
 2. ALL BOXES TO BE RAISED TO GRADE WITH NO USE OF INSERTS.

**TYPICAL SERVICE
CONNECTION DETAIL - 3/4" ~ 2"**

NOT TO SCALE

- EQUIPMENT SPECIFICATIONS**
1. ALL MATERIALS SHALL BE AWWA/NSF CERTIFIED AND APPROVED BY THE TOWN.
 2. SADDLE - ROMAC 202NS
 3. CORP STOP - BRASS NL STYLE WITH 250 psi MIN.
 4. CURB STOP - BRASS NL STYLE WITH 250 psi MIN.
 5. COPPER TUBING - TYPE 'K', SEAMLESS, 250 psi MIN.
 6. CHECK VALVES - BRASS SWING CHECK, 250 psi MIN.
 7. CURB BOX - SLIP TYPE CAST IRON
 8. BALL VALVES - BRASS BALL VALVES, 250 psi MIN.
 9. METER - (3/4" - 2") - SUPPLIED BY TOWN

**TYPICAL SERVICE
CONNECTION DETAIL**

TOWN OF BRISTOL
1 SOUTH STREET, P.O. BOX 249
BRISTOL, VT 05443
(802) 453-2410



DRAWING
W-2