

TOWN OF BRISTOL

Work in Right-of-Way and Access Permit

Office Use Only

Permit #: 26-704

Parcel #: 060280.21

Town Highway #: 25

Date Received: 6/16/2026

Fee Paid: \$100⁰⁰ #1080

Check all that apply: [] Work in Right-of-Way [☒] Access Permit (Curb Cut)

A fee of \$100 payable to the Town of Bristol for each application must be submitted.

A permit to work within the Town's right-of-way must be obtained by anyone wishing to use or work within any part of the Town's right-of-way, including but not limited to: curb cut access, water line repair, new water line connection, work on a Class 4 road, and/or projects that affect public sidewalks.

Please provide a sketch on a separate sheet of paper of the parcel and road frontage indicating the location of the proposed project, and other pertinent information, such as: existing accesses, the Town Highway, buildings, drainage ditches, fences, utility poles, and trees or plantings, etc. that may impair visibility; and other information that may be relevant.

Applicant Daniel & Mary Ann Boyd Phone 802-377-2195

Mailing address 458 Lower North Road Bristol VT 05445

E-mail address boyd453@gmail.com

Landowner Name Dan. Boyd

Property location 458 Lower North - Carlsrom Road

Town Road Name: Carlsrom Road

Town Highway #: _____

Company/Individual performing work:

Name _____ Phone: _____

Address: _____

Work in Right-of-Way

Describe project (including length, width & depth of proposed excavation)

Date of start of work TBD Date of completion TBD

The applicant agrees to maintain said access and to adhere to the terms and conditions attached to this permit. In the event all conditions of the access permit are not met within one year the town shall be authorized to affect those conditions at the landowner's expense. Please see attached terms.

TOWN OF BRISTOL

Road Frontage of Parcel (number of feet): 200 ft

Proposed Use of Driveway (check all that apply):

☐ Agricultural ☒ Single Residence ☐ Commercial
☐ Relocation ☐ Change of Use ☐ Shared Residential Driveway or
☐ Other Development Road (# Parcels)

I represent that the information contained in this application is true and that I am authorized to file this application.

Applicant's signature

6/11/2024

Date

Conditions per order of the Public Works Foreman:

Sight distance to the North is good, need to clear some brush to the South for the sight distance. Need to install a 15' x 30' grey plastic culvert in ditch with a maximum of 6" of crush gravel over the top. Need to clean the ditch on the inlet and outlet for water to get in and out of culvert if needed. Driveway needs to come in no more 2% grade either way to the road for 17' back from edge of road. Any questions call Eric at 802 373-9763

Eric Cota
7-7-26

Public Works Foreman (or designee) signature

Date _____

All access permit applications require Selectboard approval. Action by Selectboard:

Approved []

Denied []

Date: _____

Conditions of approval:

Authorized Signature: _____

Date: _____

Title: _____



Cartographic Technologies, Inc.
GIS • Tax Mapping • Programming

Bristol, VT: TownView Online
458 Lower Notch Road



Access Permit #26-704
~~Received 10/10/2022~~

RECEIVED
JUNE 16 2026

--- Approx location of subdivision
--- If required to meet 2 acre threshold