

## Bristol Town Administrator

---

**From:** Garrett Organeke <gorganeke@dubois-king.com>  
**Sent:** Friday, October 4, 2019 4:28 PM  
**To:** Bristol Town Administrator  
**Cc:** David Conger; Brandon Kipp (brandon.kipp@vermont.gov); Christopher Lathrop  
**Subject:** Re: Bristol\_Main\_St\_Alternatives\_Cost\_Estimates\_2019-08-29.xls

Good afternoon,

Below is a link to the entire Bristol-Vergennes composite plan set and estimate, with the Bristol Sidewalk and Lighting estimate highlighted.

<http://files.dubois-king.com/index.php/s/FVKgUq8wUWZayFU>

Per our Monday phone conference, here is a list of key adjustments since our August 2 submission:

- Temporary lighting will be covered by the paving project, under 641.11 Traffic Control, All-Inclusive. The state has requested that temporary lighting be required on both sides of Main Street. Below is the language that will be included in the contract.
- Confirmation of salvaged items.
- Curb along the northern side of Main St will now be removed and reset.
- Excavation pay limits have been defined in more detail.
- Imprinted concrete sidewalk band reduces from 3 ft down to 1.2 ft at Darcy's Salon in order to provide 5 ft of sidewalk.
- Light pole in front of Darcy's Salon (P8 on Electrical Plans) has been moved flush against the curb to provide 5 ft of walkway.
- 2 circuits have been added for the lights, for a new total of 4 circuits - 2 alternating circuits for each side of the street. This will leave one spare circuit.

This is the contract language for the Temporary Lighting:

21. NOTICE TO BIDDERS - TEMPORARY SIDEWALK LIGHTING REQUIREMENTS. The Contractor shall provide temporary lighting (ie illumination at finish grade) for safe pedestrian travel during the period of de-energizing the existing street lights and energizing the new street lights in Bristol from Sta. 349+91 to Sta. 354+47. The contractor shall provide lighting along both sides of Main Street. The temporary lighting shall provide light levels that meet the existing light levels of the existing street lights. The Contractor shall measure and record the existing illuminance light levels and provide an equivalent temporary lighting system. The Contractor shall provide the temporary lighting design to the engineer prior to installation. The temporary lighting system shall match the Town's current lighting sequence of operations or be adjusted per the Town's direction. As a minimum, the temporary street lighting system must be in operation from dusk to dawn. The Contractor shall make arrangements with the power utility company for service or shall provide an alternate power supply. The contractor is responsible for restoring temporary lights that are out of service within 24 hours. Payment for this work will not be paid separately, but will be considered incidental to Item 641.11 Traffic Control, All-Inclusive.

Please let us know if you have any questions.

Thank you and have a great weekend,

Garrett Organek, P.E.\*  
Project Engineer  
**DuBois & King Inc.**  
6 Green Tree Drive  
So. Burlington VT 05403  
( D ) 802.728.7239  
( O ) 802.878.7661  
\*VT

---

On Fri, Oct 4, 2019 at 3:40 PM Bristol Town Administrator <[townadmin@bristolvt.org](mailto:townadmin@bristolvt.org)> wrote:

OK—thanks!

--Valerie

Valerie Capels, Town Administrator  
Town of Bristol  
1 South Street  
P.O. Box 249  
Bristol, VT 05443  
(802) 453-2410 ext 22  
E: [townadmin@bristolvt.org](mailto:townadmin@bristolvt.org)  
W: [www.bristolvt.org](http://www.bristolvt.org)  
FB: <https://www.facebook.com/bristolvt/>  
Tw: @BristolTownAdm

---

**From:** Garrett Organek <[gorganek@dubois-king.com](mailto:gorganek@dubois-king.com)>  
**Sent:** Friday, October 4, 2019 3:36 PM  
**To:** Bristol Town Administrator <[townadmin@bristolvt.org](mailto:townadmin@bristolvt.org)>  
**Cc:** David Conger <[dconger@dubois-king.com](mailto:dconger@dubois-king.com)>; Brandon Kipp ([brandon.kipp@vermont.gov](mailto:brandon.kipp@vermont.gov))  
<[brandon.kipp@vermont.gov](mailto:brandon.kipp@vermont.gov)>  
**Subject:** Re: Bristol\_Main\_St\_Alternatives\_Cost\_Estimates\_2019-08-29.xls

Good afternoon Valerie,

It should be sent this afternoon but may be delayed until Monday morning.

Apologies for any inconvenience,

Garrett Organek, P.E.\*  
Project Engineer  
**DuBois & King Inc.**  
6 Green Tree Drive  
So. Burlington VT 05403  
( D ) 802.728.7239  
( O ) 802.878.7661  
\*VT

On Fri, Oct 4, 2019 at 3:02 PM Bristol Town Administrator <[townadmin@bristolvt.org](mailto:townadmin@bristolvt.org)> wrote:

Hi All,

Is there an ETA for the updated plans and Finance & Maintenance Agreement? I need to button up the meeting packet soon ...

Thanks!

--Valerie

Valerie Capels, Town Administrator  
Town of Bristol  
1 South Street  
P.O. Box 249  
Bristol, VT 05443  
(802) 453-2410 ext 22  
E: [townadmin@bristolvt.org](mailto:townadmin@bristolvt.org)  
W: [www.bristolvt.org](http://www.bristolvt.org)  
FB: <https://www.facebook.com/bristolvt/>  
Tw: @BristolTownAdm

---

**From:** Bristol Town Administrator  
**Sent:** Thursday, October 3, 2019 1:11 PM  
**To:** David Conger <[dconger@dubois-king.com](mailto:dconger@dubois-king.com)>  
**Subject:** Bristol\_Main\_St\_Alternatives\_Cost\_Estimates\_2019-08-29.xls

Hi David,

Thanks for your call yesterday and chat today. Attached is the most current spreadsheet I have summarizing the estimates before and after the VTrans project marriage. I'll look for the updated info and VTrans maintenance agreement Friday.

Thanks,

--Valerie

Valerie Capels, Town Administrator  
Town of Bristol  
1 South Street  
P.O. Box 249  
Bristol, VT 05443  
(802) 453-2410 ext 22  
E: [townadmin@bristolvt.org](mailto:townadmin@bristolvt.org)  
W: [www.bristolvt.org](http://www.bristolvt.org)  
FB: <https://www.facebook.com/bristolvt/>  
Tw: @BristolTownAdm